



**FESS FIRE**  
**FIRE EXTINGUISHER SERVICES (PTY) LTD**  
 COMPLETE FIRE PROTECTION

17 Angle Road  
 New Doornfontein  
 Johannesburg  
 2094

PO Box 17050  
 Doornfontein  
 2028

TEL: (+27 11) 402 5063/4  
 FAX: (+27 11) 402 5080

E-MAIL: info@fessfire.co.za  
 WEBSITE: www.centa.co.za

FESS & Fire Extinguisher  
 Services (Pty) Ltd  
 Registration 1971/000018/07

**LETTER OF COMPLIANCE**

THIS LETTER SERVES TO STATE THAT IN OUR PROFESSIONAL OPINION,  
 BASED ON OUR INTERPRETATION OF EXISTING REGULATIONS,  
 THE FIRE EXTINGUISHERS, HOSE REELS & SYMBOLIC SIGNS AT

BACK-UP STORAGE FACILITIES

ALRODE

HAVE BEEN SUPPLIED, INSTALLED AND MAINTAINED IN ACCORDANCE WITH SANS 1475  
 AND COMPLY WITH THE BASIC REQUIREMENTS OF THE FOLLOWING REGULATIONS:

**SANS 10400 / SANS 10105 / SANS 1475**  
**THE OCCUPATIONAL HEALTH AND SAFETY ACT OF 1993**

AS SUCH, THE FIRE EXTINGUISHERS, HOSE REELS & SYMBOLIC SIGNS  
 THROUGHOUT THE ABOVE-NAMED PREMISES SHOULD PROVIDE THE NECESSARY  
 LEVEL OF FIRE PROTECTION, AND ARE SUITABLE FOR USE ON THE FOLLOWING:

<b>CLASS A</b>	<b>Wood, Paper and Textile type Fires</b>
<b>CLASS B</b>	<b>Flammable Liquid and Gas type Fires</b>
<b>CLASS C</b>	<b>Fires in the presence of Live Electricity</b>

MAINTENANCE AND UPGRADING OF THE FIRE EXTINGUISHERS, HOSE REELS &  
 SYMBOLIC SIGNS MUST BE CARRIED OUT ON AN ANNUAL BASIS IN ORDER TO ENSURE  
 CONTINUED COMPLIANCE WITH ONGOING CHANGES TO THE ABOVE REGULATIONS

**FESS FIRE EXTINGUISHER SERVICES (PTY) LTD**

HEREBY ASSURE YOU OF OUR BEST ATTENTION AT ALL TIMES IN MATTERS  
 RELATING TO FIRE PROTECTION, FIRE PREVENTION AND GENERAL SAFETY  
 K24603

20 July 2015

DATE OF ISSUE

JOEL BARNATO

Name

Signature

ISSUED BY

**Note:** In view of the fact that certain sections of the regulations are open to interpretation, the local  
 fire authorities may deem it necessary to insist on the installation of additional equipment.

DIRECTORS: J. Kellett • J. Barnato (Alt)

**ACCREDITATIONS**

